

DISTRICT WATER TESTING LABORATORY, JALANDHAR
Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com

To,

Pioneer International Public School, Mithra Road, V.P.O. Rurka Kalan, Jalandhar.
Distt. Jalandhar.

No. DWTJAL/2627/00010 Dated : 10/04/2026

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 47 Dated: 07/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 09/04/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Jalandhar



DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dori, Near DC Office, Jalandhar
dwtjalandhar@gmail.com



TC-14420

TEST REPORT

Name & Address of Customer Pioneer International Public School, Mithra Road, V.P.O. Rurka Kalan, Jalandhar Distt. Jalandhar.		Customer Reference No.	No : 47 Dated : 07/04/2026
		Sample Submitted by	Sh. Karan Kishore (J.E.)
		Date of Sample Receipt	09/04/2026
		Analysis Starting Date	09/04/2026
		Analysis completion Date	10/04/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC144202600000120F	Sample Type :	Water
Test Report No.:	DWTJAL/2627/00010	Date of Issue :	10/04/2026
Registration No.:	DWTJAL/REG2627/00013	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Pioneer International Public School, Mithra Road, V.P.O. Rurka Kalan, Jalandhar.(P/Sub.) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Jalandhar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.64@26°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	515.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.63	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	389.76	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	444.72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	119.37	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	35.69	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B. By Calculation Method
11	Chloride(Cl)	49.40	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. * Temperature condition limit: 25±5°C and Humidity condition limit 50 ±20%

Reviewed and Approved By

(Signature)

Mr. Jivesh Kumar
Microbiologist/Analyst
Authorized Signatory
For, District water Testing Laboratory
Jalandhar



End of the Test Report